



Michaud K491 (Network approved fuse base)
Fuse bases on galvanized bracket
Refer to manufactures instructions
for installation requirements

Single Phase Example

3 Phase Example

Network Approved
Connectors

3 x Stainless Steel
'Bandit' Straps

White Pressure Duct
Suitable size for LV Cable.

LV Cable Min 600mm
Depth

Orange Duct Sweep Bend
Suitable size for LV Cable.

<p>28 Mt Pleasant Road Whangarei New Zealand Private Bag 3018</p> <p>Phone +64 9 430 1803 Fax +64 9 430 1804 www.northpower.com</p>	REV	DESCRIPTION	DSN	DRN	CHKD	APPD	DATE	Pole Structures			STATUS	Construction		
	A-1	Initial Design	CP	CP	CJP	SB	15/03/19	Typical LV Riser Cable Arrangement			SCALE	NTS	SIZE	A3
B	Add single phase sample. Change Status to Construction	CP	CP	CJP	SB	15/03/19				PLAN NO.	2F359			
-	-	-	-	-	-	-	-				SHEET	1		
-	-	-	-	-	-	-	-				REV	B		